



## SUPPLEMENTAL BID BULLETIN 01

August 15, 2022

**SUBJECT: Bid Reference No: 2022-38 SUPPLY, INSTALLATION & COMMISSIONING OF STAND-BY GENERATOR SET WITH COMPLETE ACCESSORIES AND CABLING FOR MAIN BUILDING"**

This Supplemental Bid Bulletin No. 1 is issued to all participating bidders to clarify, amend and/ or modify certain provisions and requirements set forth under the above-entitled procurement project:

### Bid Data Sheet

FROM/ Bidder's Inquiry	TO/ BFAR Response
<b>Deadline of submission and receipt of bids</b>  <b><u>August 22, 2022 (Monday) at 10:30 AM</u></b> at the 2 <sup>nd</sup> Floor, BAC Secretariat Office, Fisheries Building Complex, BPI Compound, Brgy. Vasra, Q.C., and electronic documents through <a href="mailto:bac.eps@bfar.da.gov.ph">bac.eps@bfar.da.gov.ph</a>	<b>Deadline of submission and receipt of bids</b>  <b><u>August 30, 2022 (Tuesday), 10:30 a.m.</u></b> at the 2 <sup>nd</sup> Floor, BAC Secretariat Office, Fisheries Building Complex, BPI Compound, Brgy. Vasra, Q.C., and electronic documents through <a href="mailto:bac.eps@bfar.da.gov.ph">bac.eps@bfar.da.gov.ph</a>
<b>Schedule of Bid opening</b>  <b><u>August 22, 2022 (Monday) at 11:00 AM</u></b> via Zoom	<b>Schedule of Bid opening</b>  <b><u>August 30, 2022 (Tuesday), 11:00 am</u></b> via Zoom
For this purpose, contracts similar to the Project refer to contracts which have the same major categories of work, which shall be:  <b>a.</b> Lot 1 – Installation of at least two (2) units of 250KVA to government or private agency.  <b>b.</b> Completed within years (5) years prior to the deadline for the submission and receipt of bids.  <b>Multi-Fold Links</b>  1. We would like to request consideration to change the SLCC primary purpose to:  "Installation of at least one (1) or cumulative of 250 KVA Genset to government or private agency" since the project scope of works only requires one (1) unit of 250 KVA generator set.  In Addition, please confirm if the bidder is also allowed to provide an SLCC contract that is	<b>1. Approve. The bidder may supply one (1) unit 250 KVA generator set or cumulative units (one project) with a total or more than 250 KVA.</b>  <b>2. Approve.</b> Similar projects must be completed <b>within ten (10) years</b> prior to the deadline for the submission and receipt of bids.

higher than 250 KVA genset capacity.

2. We would like to request consideration to lift the prescription period of the SLCC and make it longer from 5 years to 10 years.

Reason: In the last 3 years, half of it was and still is within the pandemic quarantine period which again is very evident that business and technology projects were almost at a standstill. Work in the private and/or government sector has been suspended due to the quarantine restrictions. Even GPPB, prior to the pandemic period, has expressed consideration of longer years of similar completed projects to encourage more participation from qualified bidders.

In addition, the mode of procurement for this project is infrastructure. The procuring entity may consider contracts of the corresponding certificate of completion for which was issued within ten (10) years from the date of submission and receipt of bids.

#### **10.4. Key Personnel Requirement**

<b>Expertise</b>	<b>No.</b>	<b>Min. Years of Experience</b>	<b>Remarks</b>
<b>Civil Engineer</b>	1	at least three (3) years	should be a Registered Civil Engineer and regular employee with at least three (3) years' experience as civil engineer. Trained in Generator Set.

**10.5** Minimum major equipment requirements are the following:

<b>Description</b>	<b>Owned/Leased</b>	<b>Total</b>
Bagger mixer	1	1

#### **10.4. Key Personnel Requirement**

<b>Expertise</b>	<b>No.</b>	<b>Min. Years of Experience</b>	<b>Remarks</b>
<b>Civil Engineer</b>	1	at least three (3) years	should be a Registered Civil Engineer and regular employee with at least three (3) years' experience as civil engineer. <b>Trained in Generator Set.</b>

**Must submit Curriculum Vitae and training certificate for ALL key personnel**

**10.5** Minimum major equipment requirements are the following:

<b>Description</b>	<b>Owned/Leased</b>	<b>Total</b>
Bagger mixer	1	1

Elf truck	1	1	Elf truck or <b>Pick-up truck</b>	1	1
<b>Multi-Fold Links</b>  We would like to request for consideration to allow the Elf truck or <b>Equivalent Pick-up truck</b> as part of the major equipment requirements.					

### Technical Specifications

FROM/ Bidder's Inquiry Terms of Reference	TO/ BFAR Response Terms of Reference
<b>2. GENERATOR SET</b>  2.1. Supply and installation of 1-unit 250kVA, 240V, 60Hz, 3 phase, prime power, silent type Generator set with the following specifications	<b>2. GENERATOR SET</b>  2.1. Supply and installation of 1-unit 250kVA, 240V, 60Hz, 3 phase, <b>STANDBY prime-power</b> , silent type Generator set with the following specifications
<b>4.MECHANICAL WORKS</b>  4.1. Supply, delivery, and installation of 2000 liters capacity fuel day tank (FDT) 4.2. Provision of 2000 liters diesel initial load to FDT.	<b>4.MECHANICAL WORKS</b>  4.1. Supply, delivery, and installation of <b>1000 liters for the generator set, 2000 liters capacity</b> fuel day tank (FDT) 4.2. Provision of <b>1500</b> liters diesel initial load to FDT.
	<b>Submit Certificate of Site Inspection. Coordinate with Engr. Noel Espiritu-09989857898</b>

\*\*\*nothing follows\*\*\*

All other portions of the Bidding Documents affected by these amendments shall be made to conform the same.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

The changes made in the Philippine Bidding Documents (6th Edition, July 2020) are deemed integrated in terms and conditions for this project.

For further inquiries, please coordinate/call the Bids and Awards Committee Secretariat at Tel. No. 8332-4661 or bac.eps@bfar.da.gov.ph.

Please be guided accordingly.

**NAPOLEON SALVADOR LAMARCA JR.**  
Vice-Chairperson, BAC