

Republic of the Philippines Department of Agriculture Bureau of Fisheries and Aquatic Resources BIDS AND AWARDS COMMITTEE OFFICE

2/F Fisheries Bldg. Complex, BPI Compound, Brgy. Vasra, Visayas Ave., Quezon City, Philippines

Tel. No.: +02. 332. 4661 website: www.bfar.da.gov.ph e-mail:

bac.eps@bfar.da.gov.ph

SUPPLEMENTAL BID BULLETIN NO. 1

24 April 2023

SUBJECT: BID REFERENCE NO. 2023-22 entitled "SUPPLY, DELIVERY, AND INSTALLATION OF SOLAR INVERTER/HYBRID BATTERY IN MULTI-MISSION CENTER (MMC) IN SITIO CARBON, LAJALA,

CORON, PALAWAN"

This Supplemental Bid Bulletin No. 1 is issued to all participating bidders to clarify, amend, and/or modify certain provisions and requirements set forth under the abovementioned procurement project, to wit:

Section V. SPECIAL CONDITIONS OF THE CONTRACT

<u>FROM</u>	<u>T0</u>
Delivery and Documents	Delivery and Documents
· · ·	Lot 1-within one hundred twenty (120) calendar days from receipt of the Notice to Proceed

Section VI. SCHEDULE OF REQUIREMENTS

FROM	TO
DELIVERED, WEEKS/MONTHS	DELIVERED, WEEKS/MONTHS
Notice to Proceed (NTP) by the winning bidder.	Within one hundred twenty (120) calendar days from receipt of Notice to Proceed (NTP) by the winning bidder.

Section VII. TECHNICAL SPECIFICATIONS

FROM	<u>T0</u>
TERMS OF REFERENCE	TERMS OF REFERENCE
	Delivery: one hundred twenty (120) calendar days upon receipt of the Notice to Proceed

(To include in the Terms of Reference)
Other Requirements:
 The bidder shall submit a Certificate of Site Inspection from PFO Rey Templonuevo of BFAR MMC Sitio Carbon, Lajala, Coron, Palawan; and
 The bidder/supplier shall provide a Warranty Certificate of six (6) years for the inverters and five (5) years replacement warranty for the battery.

	BIDDERS' INQUIRY	BFAR RESPONSE
1.	Is there an existing Solar Panel?	 Yes, there is an existing Photo Voltaic (PV) panel.
2.	What is the existing voltage?	2. The required voltage for the utilization of the electrical power is 220V.
3.	Are we going to use the existing electrical components?	3. We consider using new electrical components that is compatible to the new installation.
4.	What is the required battery back-up time?	4. The battery backup time is irrelevant since we don't have a backup battery bank.
5.	Do you require a Certificate of site inspection as part of the eligibility requirements?	5. Yes, we require a certificate of site inspection as part of the eligibility requirements.
6.	Regarding on Terms of Reference (TOR), page 32 of the bidding documents under scope of work item II-C, is the 10.24kw storage battery for 10.6kwp solar?	6. Yes, 10.24KW storage battery and 10.6 KWP.
7.	Regarding the Single Largest Completed Contract (SLCC), do you consider Supply, Delivery, and Installation of Solar Power System as similar of this project?	7. Yes, we consider it as a similar project.
8.	With regards on delivery lead time, can we extend from fifteen (15) calendar days to one hundred twenty (120) calendar days?	8. Yes, we consider 120 calendar days for this project.

All other portions of the Bidding Documents affected by these amendments shall be made to conform the same.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

The changes made in the Philippine Bidding Documents (6th Edition, July 2020) are deemed integrated with the terms and conditions for this project.

For further inquiries, please coordinate/call the Bids and Awards Committee Secretariat at Tel. No. 8332-4661.

Please be guided accordingly.

ORIGINAL SIGNED

NAPOLEON SALVADOR J. LAMARCA

Vice-Chairperson, Bids and Awards Committee